



2012000586E



检测
CNAS L0690

TEST REPORT

(No): 20131C00402



Entrusted by:

Nanjing Xuhua Sundi New Building Materials
Co.,Ltd

Sample Name:

Wood-plastic composite flooring

Test Type:

Entrustment test

**National Research Center of Testing
Techniques for Building Materials**



A 1195466



2012000586E

National Research Center of Testing Techniques for Building Materials Test Report

No: 20131C00402

Page 1 of 2

Sample name	Wood-plastic composite flooring	Test type	Entrustment test
Entrusted by	Nanjing Xuhua Sundi New Building Materials Co.,Ltd	Brand	_____
Manufacturer	Jiangsu Xuhua Sundi Building Materials Co.,Ltd	Sample description	The sample is intact
Date of reception	Mar.6th.2013	Sample No.	_____
Date of produce	Feb.21th.2013	Batch No.	_____
Model /Size	500mm ×150mm×30mm	Quantity of Sample	20pieces
standard/meth od	GB/T 24508-2009 Wood-plastic composite flooring		
Test items	1.Size change rate of water absorption 2.Bending load 3.Falling ball impact in room temperature 4.Resistance to freeze-thaw 5.Cool-heat cycling test 6.Density 7.Surface abrasion 8.Determination of water absorption 9.Size change degree after calefaction 10.Falling ball impact in low temperature 11.Formaldehyde emission 12.Rate of creep recovery		
Test conclusion	*The sample(s) tested complies with the requirements of GB/T 24508-2009.* Issued date : Mar.28th.2013 (cachet)		
Remarks: (Blank)			

Approved by:

Verified by:

Compiled by:

Address: No.1 Guanzhuang Dongli,Chaoyang District, Beijing (100024) TEL: 65728538

National Research Center of Testing Techniques for Building Materials Test Report

No: 20131C00402

Page 2 of 2

No.	Test items		Requirements of standard		Test results	Individual conclusion	
1	Size change rate of water absorption		Longitudinal direction $\leq 0.3\%$		0.04%	Pass	
			Widthwise direction $\leq 0.4\%$		0.16%	Pass	
			Thickness direction $\leq 0.5\%$		0.11%	Pass	
2	Bending load		Public places $\geq 2500\text{N}$ Non - public places $\geq 1800\text{N}$		6744N	Pass	
3	Falling ball impact in room temperature		The diameter of the pit $\leq 12\text{mm}$		9mm	Pass	
4	Resistance to freeze-thaw		Retention rate of bending load $\geq 80\%$		96%	Pass	
5	Cool-heat cycling test	Appearance	No bubbles,cracks		No bubbles,cracks	Pass	
		Dimensional change	$\leq 0.5\text{mm}$		0.35mm	Pass	
6	Density		$\geq 0.85\text{g/cm}^3$		1.30g/cm^3	Pass	
7	Surface abrasion		$\leq 0.15\text{g/100r}$		0.09g/100r	Pass	
8	Determination of water absorption		Foaming $\leq 10.0\%$ Non-foaming $\leq 3.0\%$		0.5%	Pass	
9	Size change degree after calefaction		Front	Back	$\pm 1.0\%$	Front -0.3% Back -0.3%	Pass
			Difference in the rate of change		$\leq 0.5\%$	0.07%	Pass
10	Falling ball impact in low temperature		-10°C , No crake		-10°C , No crake	Pass	
11	Formaldehyde emission		$E_0 \leq 0.5\text{mg/L}$ $E_1 \leq 1.5\text{mg/L}$		$< 0.1\text{mg/L}$	Pass	
12	Rate of creep recovery		$\geq 75\%$		85%	Pass	
Remarks: (Blank)							

Address: No.1 Guanzhuang Dongli, Chaoyang District, Beijing (100024) TEL: 65728538

说 明

Notice

- 1、本报告无中心“检验专用章”和骑缝章无效。

This test report is invalid without the seal.

- 2、本报告无“编制、审核、批准”签字无效。

This test report is invalid without the signatures of the related persons.

- 3、本报告涂改、部分复印无效。

This test report is invalid if erased, altered or copied partially.

- 4、对本报告若有异议，应于收到报告之日起十五日内向本中心提出，逾期恕不受理。

Any doubt should inform us within 15 days after receiving the test report.

- 5、委托检验样品和委托信息由委托人提供，中心不对其真实性负责，委托检验结果仅对来样负责。

The commissioned testing samples and commission information are provided by the applicant. The results shown in the test report refer only to the sample(s) tested unless otherwise stated. Identifying authenticity of the supplied samples and information is out of our responsibility.

- 6、本报告采用防伪纸张，复印后应带有网格底纹，数据页背面的编号为随机编号，与报告内容无关。

This test report is printed on anti-counterfeiting paper. Its copy should have grid shading. The numbers on the back of the data sheet are random numbers not related with the report.

本中心联系方式：

地址（Address）：北京市朝阳区管庄东里1号

No.1 Guanzhuang Dongli, Chaoyang District, Beijing 100024, P.R. China.

邮编（Post Code）：100024

电话（Tel）：（86-10）65728538 51167681 / 7983 / 7984

传真（Fax）：（86-10）65715991

报告真伪查询：Tel:（86-10）51167679

Fax:（86-10）65764684

网址（Web）：<http://www.cbmtc.com>

www.chinabmnet.com

www.ctc.ac.cn

电子邮箱（E-mail）：baogao@ctc.ac.cn



ISO9001
中国建材认证
China Building Material Certification



ISO14001
中国建材认证
China Building Material Certification



服务认证



GB/T 28001
中国建材认证
China Building Material Certification



产品认证
中国建材认证
China Building Material Certification